



SOUTH METRO FIRE DEPARTMENT

1650 Humboldt Avenue • West St. Paul MN 55118

Phone: (651) 552-4176 • FAX: (651) 552-4195

www.southmetrofire.com

Inspection Form for Sale of Consumer Fireworks in a Retail Facility/Stand

- Must be classified as Mercantile (Group M)
- No Vehicle parking within 10’.
- 10’/20’ clearance from combustibles.
- 2 Portable fire extinguisher with a minimum 2A rating
- Shelving not to exceed 6’ in height.
- Flame breaks* are required at least every 16’ or if fireworks are packaged at least every 32’.
- Shelving not more that 10% open (holes or other openings)
- No storage or sale of fireworks within 5’ of the public entrance or 2’ of a private entrance.
- No Smoking Signs Posted at entrances.
- All electrical wiring shall be in accordance with NFPA 70
- Means of Egress
 - Required means of egress shall not pass through storage rooms
 - Two exits shall be provided
 - Aisle with 48” minimum
 - Aisle width unobstructed at all times the facility is occupied
 - Maximum travel distance from the most remote point not to exceed 75’
 - Exit signs shall be self-luminous or internally or externally illuminated
 - Emergency lighting shall be illuminated whenever the facility is occupied in accordance with MSFC
- Training:
 - No sales to anyone under 18 years of age or persons who are obviously under the influence of alcohol or drugs.
 - Remove, do not sell damage packages.
 - Use Brooms or brushes to clean loose pyrotechnic composition, no mechanical cleaning devices.

*Definition of Flame Break NPFA 1124:

A solid material without holes or other openings, used to retard the spread of flame. The flame break shall extend as follows, from the display surface to not less than 6” above the full height of the displayed merchandise or to the underside of the display surface directly above for the full depth of the displayed merchandise.

SITE NAME:	
SITE ADDRESS:	
MANAGER NAME:	
DATE INSPECTED:	

